

IZMERJENE VREDNOSTI POSAMEZNIH PARAMETROV 2023 - VS OTALEŽ

DATUM VZORČENJA

PARAMETER	Normativ	7. 2.	8. 3.	21. 6.	25. 7.	22. 8.	11. 9.	12. 12.
Okus	≤ 1		1				1	brez
Temp. vode (°C)		6,8	5,5				18,4	
pH	6,5 - 9,5		7,9				8,0	8,1
Elektr. prevodnost (μS/cm)	≤2500		310				325	256
Vonj	≤ 1		1				1	brez
Motnost (NTU)	≤ 4		0				0	< 0,1
E. coli (/100 ml)	0		0	0	0	0	0	0
Št. kolonj pri 22°C (/ml)	≤ 100		1	0	2	2	0	0
Št. kolonj pri 37°C (/ml)	≤ 100		0	0	0	3	0	0
Cl. perfringens (/100 ml)	0		0				0	0
Enterokoki (/100 ml)	0		0	0	0	0	0	0
Koliformne bakterije (/100 ml)	0		0	0	0	0	0	0
Klor prosti (mg/l)		0,15	0,11				0,11	
Trihalometani - vsota (μg/l)	≤ 100	2,6						
Barva (/m)	≤ 0,5							< 0,2
Amonij (mg/l)	≤ 0,5							< 0,02
Klorat (mg/l)			0,06					
Klorit (mg/l)			< 0,05					