

IZMERJENE VREDNOSTI POSAMEZNIH PARAMETROV 2023 - VS ŠEBRELJE

DATUM VZORČENJA

PARAMETER	Normativ	25. 1.	8. 6.	11. 7.	22. 8.	16. 11.	30. 11.
Okus	≤ 1		brez	1			1
Temp. vode (°C)		5,7		19,5			10,1
pH	6,5 - 9,5		7,6	7,6			8,0
Elektr. prevodnost (μS/cm)	≤2500		130	200			256
Vonj	≤ 1		brez	1			1
Motnost (NTU)	≤ 4		0,4	0,0			0
E. coli (/100 ml)	0		0	0	0	0	0
Št. kolonj pri 22°C (/ml)	≤ 100		0	0	0	0	0
Št. kolonj pri 37°C (/ml)	≤ 100		0	0	0	0	1
Cl. perfringens (/100 ml)	0			0	0		0
Enterokoki (/100 ml)	0		0	0	0		0
Koliformne bakterije (/100 ml)	0		0	0	0	0	0
Klor prosti (mg/l)		0,08		0,10			
Trihalometani - vsota (μg/l)	≤ 100	< 0,5					
Barva (/m)	≤ 0,5		< 0,2				
Amonij (mg/l)	≤ 0,5		< 0,02				
Klorat (mg/l)				< 0,05			
Klorit (mg/l)				< 0,05			